

SALT SPRAY RESISTANCE DECLARATION

I, Ms M^a Isabel Martinez Valdelvira, acting in my capacity as MANAGING DIRECTOR and representative **DECOPROYEC SUBERTRES S.L.U.**, company tax identification number (CIF): B-02528978, with its registered office at C/Trilladores nº47 Nave 4 y 5, 02520 Chinchilla de Montearagón (Albacete), Spain.

HEREBY DECLARE

That the product **DECOPROYEC SPRAYED CORK COATING**, manufactured at our production facility located at C/Trilladores nº47 Nave 4 y 5, 02520 Chinchilla de Montearagón (Albacete), Spain, has been subjected to the test entitled *"Resistance and Performance in a Saline Environment"*, in accordance with standard UNE-EN ISO 9227:2006.

The test consists of subjecting a series of standardised test specimens to 1,000 hours of continuous exposure in a salt spray chamber equipped with nozzles spraying a sodium chloride solution at a concentration of 50 g/l, with the salt spray directed at an angle of 20° to the vertical.

The test results were satisfactory and positive, as stated in report IT130117 issued by AIDICO, an officially accredited laboratory. The conclusions of the report specifically highlight that, following 1,000 hours of exposure to salt spray, no visible changes were observed, nor were any changes or defects in adhesion detected between the spray-applied cork coating and the substrate to which it had been applied.



Fdo: M^a Isabel Martínez Valdelvira